

Addendum # 1
Request for Proposal
Almon Road Culvert Improvement
Issued September 22, 2016

Please find enclosed Addendum #1 to the above referenced project for the City of Carrollton, Georgia. Included in this addendum are the following documents that replace the original sections and sets of drawings in their entirety:

Special Conditions - 2 pages

The bid proposal opening date has been postponed from Thursday, September 29, 2016 to Thursday, October 13, 2016. The selected proposal is scheduled to be presented at the Mayor and Council Meeting on November 7, 2016.

The revised bid opening is 10:00 a.m., Thursday, October 13, 2016.

Clarifications:

The contractor will not be required to lower the level of Lake Carroll, as previously stated in the special conditions. The contractor will be required to install Cofferdam/Bypass Pump as needed for the proper installation of the culvert and improvements.

Soil Erosion and Sediment Controls. Appropriate soil erosion and sediment controls must be used and maintained in effective operating condition during construction, and all exposed soil and other fills, as well as any work below the ordinary high water mark or high tide line, must be permanently stabilized at the earliest practicable date. Permittees are encouraged to perform work within waters of the United States during periods of low-flow or no-flow.

Removal of Temporary Fills. Temporary fills must be removed in their entirety and the affected areas returned to pre-construction elevations. The affected areas must be revegetated, as appropriate.

Sincerely,



Tommy J. Holland, P.E.